

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190221-R15431  
**Report Reference** R15431-20061130  
**Issue Date** 2019-FEBRUARY-21

**Issued to:** HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC  
7250 Dallas Pky, Legacy Tower Suite 1000  
Plano TX 75024

**This certificate confirms that  
representative samples of**

FIRESTOP DEVICES  
See Addendum page

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 1479- Fire Tests of Through-Penetration Firestops  
**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190221-R15431  
**Report Reference** R15431-20061130  
**Issue Date** 2019-FEBRUARY-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Firestop devices for use in specific through-penetration firestop systems. The various suffixes for the designations of the firestop devices indicate the maximum nominal outside diameter of the penetrant for which the device is intended. The "-M" devices are intended for use with metallic penetrants and the "-P" devices are intended for use with nonmetallic penetrants.

**Models:**

CP 680-M 2", 3", 4" and 6".

CP 680-P 2", 3", 4" and 6".

CP 680-PX 2" and 3"



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

